

UNDERWRITERS LABORATORY (UL) LISTING

Dripstops 920, 940; Nuts N' Bolts 427; Self Sealers 604, 615, 616, 618:



Grade numbers [Dripstop 920](#), [940](#), [Nuts n' Bolts 427](#), and [Self Seeler 604](#), [615](#), [616](#) and [618](#) have been tested and classified by Underwriters Laboratories Inc. as to fire hazard only: Fire hazard is small; No flash [point](#) in liquid state; Ignition temperature 837°F (447°C). Suitable for use in devices handling gasoline, petroleum oils, natural gas (pressures not to exceed 300 psig), propane, and butane. 29R9 Reference: Underwriters laboratory File Number MH14222.